



HAILEY FIRE DEPARTMENT

APPLICATION FOR SAFE AND SANE FIREWORKS PERMIT

PLEASE RETURN THE COMPLETED APPLICATION FORM WITH THE FOLLOWING ITEMS BEFORE **JUNE 1ST**:

- \$100.00 PERMIT FEE
- \$50.00 INSPECTION FEE includes required Pre-Installation Inspection, Installation Inspection and Clean-Up Inspection. Any subsequent inspections may be subject to additional inspection fees as outlined in the Hailey Fire Dept. Permit Fee Schedule.
- COMPLETE LIST OF FIREWORKS TO BE SOLD
- LEGAL DESCRIPTION AND SITE PLAN WITH REQUIRED SETBACKS OF FIREWORKS SALE LOCATION
- WRITTEN PROOF OF OWNERSHIP OR AUTHORIZATION TO USE PROPERTY FOR FIREWORKS SALES
- CERTIFICATE OF INSURANCE (5.24.090) ONE HUNDRED THOUSAND DOLLARS PER OCCURANCE
- \$100.00 CLEAN-UP BOND (5.24.080)

APPLICANT'S FULL NAME: _____

BUSINESS NAME: (If applicable) _____

PHYSICAL ADDRESS OF APPLICANT: _____

MAILING ADDRESS OF APPLICANT: _____

(IF DIFFERENT FROM ABOVE)

APPLICANT PHONE: _____ DATE OF BIRTH: ____/____/____

APPLICANT'S STATE SALES TAX PERMIT NUMBER: _____

PROPOSED LOCATION OF FIREWORKS STAND: _____

PROPERTY OWNER NAME: _____

PROPERTY OWNER MAILING ADDRESS: _____

PROPERTY OWNER PHONE: _____

Please attach the names, addresses and phone numbers of Principal Officers, Trustees, and or Directors if any, of the Applicant.

I declare under penalty of perjury that the above information contained herein is to the best of my knowledge and belief true and correct. I further declare that I have read the rules and regulations which concern the retail sale and storage of fireworks in the City of Hailey and will abide by the contents therein.

Signature

Title

Printed Name

Date

These guidelines are meant to assist the applicant in the completion of the Safe and Sane Fireworks Permit Application. It is in no way meant to substitute City of Hailey Municipal Code Section 5.24 pertaining to Fireworks in the City of Hailey.

- (1) Applicant must be 21 years of age or older to apply for a safe and sane fireworks permit.
- (2) A site map of the location and a detailed list of each type of fireworks that will be offered for sale, possessed, used, kept or stored must be submitted with the safe and sane fireworks permit application.
- (3) Each applicant must file with the fire chief prior to issuance of permit an insurance policy or certified copy of public liability and products liability insurance on occurrence basis coverage. Applicants for a safe and sane fireworks permit shall carry public liability insurance with a combined bodily injury and property damage of one hundred thousand dollars per occurrence. Each policy of insurance shall be in a form and substance acceptable to the City and shall name as insured parties under the terms of the policy the city, all officials of the city in performance of official functions regarding all operations under or pertaining to said permit, any licenses or licensor of the applicant, and all vendors of the fireworks covered by the permit to be issued to the applicant. The policy of insurance shall be underwritten through or by a qualified and duly licensed insurance company or companies doing or authorized to do insurance business in Idaho. Said policy of insurance shall be so written that it cannot be cancelled without at least ten days prior written notice to the city from the underwriting insurance company.
- (4) All retail sales of safe and sane fireworks shall be permitted only from within a temporary fireworks stand, and the sale from any other building, structure or building is hereby prohibited.
- (5) The stand in which the fireworks will be stored or sold shall not be located within twenty five feet (25') of any other building nor within one hundred feet (100') of any flammable liquid dispensing device or installation.
- (6) All fireworks stands must meet the structural stability requirements of the International Building Code, but using only a twenty p.s.f. roof loading and fifteen p.s.f. wind loading. The structure need not be mounted on a permanent foundation, but must be securely anchored to prevent horizontal movement and/or vertical uplift. All lighting circuits and other electrical equipment shall be approved by the State of Idaho Electrical Inspector.
- (7) The stand shall have two exit doors each a minimum of thirty inches wide one at each end of the stand or as near the ends as is practical. One additional door is required for each thirty-two feet or rear wall in excess of thirty-two feet. All doors shall open outward from the stand and all doorways shall be kept unlocked and unlatched during the hours of operation and free and clear from all supplies and materials at all times.
- (8) A stand shall have at least two (2) approved two and one-half (2-1/2) gallon water type fire extinguishers, or two (2) dry chemical type fire extinguishers having a 2A minimum rating, or a combination of both, in good working order, with a current inspection tag in place, placed near the exits in a visible and readily accessible manner. Extinguishers shall be placed apart near the exits no more than twenty lineal feet apart. If the distance exceeds twenty lineal feet, more extinguishers shall be required.
- (9) A stand shall meet the minimum requirements for temporary buildings for all lighting circuits or other electrical equipment used in conjunction with the operation of the stand as required by applicable local building codes or, if no local building codes have been adopted, then by applicable state codes.
- (10) There shall be at least one supervisor nineteen years of age or older, on duty at all times. All fireworks shall be effectively kept away from any kind of self service by the public, and shall be placed in a location which is unavailable and inaccessible to members of the public in capacities other than as legal customers. No person under fifteen (15) years of age shall work at or about any stand where safe and sane fireworks are sold or offered for sale.
- (8) No person employed or functioning as a watchman shall be permitted to remain inside of any stand when it is not open for business.
- (9) "No smoking" signs with minimum lettering size not less than 1 1/2" high and 1/4" stroke width or approved international symbol signage shall be prominently displayed both inside and outside the stand. Smoking shall not be permitted within the stand or within twenty five feet (25') of the stand.
- (10) No fireworks shall be discharged in or within fifty feet of any fireworks stand.
- (11) No person shall allow any rubbish or weeds to accumulate in or around any fireworks stand or permit a fire nuisance to exist. At least one twenty gallon non-combustible metal garbage can with lids must be provided on the premises. This can must be emptied at least once daily.
- (12) Fireworks for sale or in storage shall not be left unattended at any time. Fireworks shall be stored in areas approved by the Fire Chief or his designated representative.
- (13) Fireworks shall not be left in the stand when it is not open for business unless the stand is locked or secured. If fireworks are not stored in the stand they shall be stored in compliance with Idaho Code Section 39-2608.
- (14) No stand shall have a floor area in excess of four hundred square feet.
- (15) Stands shall be erected only in locations where zoning, under the zoning ordinance of the city, is business.
- (16) Fireworks shall not be sold to minors under fifteen years of age. "No Sales to Minors Under Fifteen Years of Age" signs with minimum lettering size not less than one and one-half inches high and one-fourth inch stroke width or approved international symbol signage shall be prominently displayed both inside and outside the stand.
- (17) Each permittee shall be required to retain at the licensed premises, while said premises are open, and at his principal place of business for a year thereafter, copies of all invoices, receipts, and orders evidencing the source from which he acquired the fireworks which he/she handled.
- (18) Safe & Sane Only:** Product must have "Safe & Sane" stamp or be submitted to HFD for testing prior to issuance of permit.